

Annual Drinking Water Quality Report

Town of Wise Water Treatment Plant
PWSID # 1195950

INTRODUCTION

This Annual Drinking Water Quality Report for calendar year 2020 is designed to inform you about your drinking water quality. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH).

If you have questions about this report, please contact: **Caleb Ramsey** **Phone: (276)-328-6353**

If you want additional information about any aspect of your drinking water or want to know how to participate in decisions that may affect the quality of your drinking water, please contact: **Caleb Ramsey** **Phone: (276)-328-6353**

The times and location of regularly scheduled Town Council meetings are as follows: **4th Tuesday of each month at 7:00 P.M.**

GENERAL INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also, come from gas stations, urban storm water runoff, and septic systems. (5) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care

providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

SOURCE(S) OF YOUR DRINKING WATER

The source(s) of your drinking water is (X) surface water () groundwater () groundwater under the direct influence of surface water as described below:

Our water source is the 318 million gallon Bear Creek Reservoir, a surface water supply located on Coeburn Mountain Rd.

The Virginia Department of Health conducted a source water assessment of our system during 2019. The Bear Creek Reservoir and Bear Creek was determined to be of high susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program. The report is available by contacting Caleb Ramsey at the phone number or address given elsewhere in this drinking water quality report.

DEFINITIONS

Contaminants in your drinking water are routinely monitored according to Federal and State regulations. The table on the next page shows the results of our monitoring for the period of January 1st to December 31st, 2020. In the table and elsewhere in this report you will find many terms and abbreviations you might not be familiar with. The following definitions are provided to help you better understand these terms:

Maximum Contaminant Level, or MCL - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal, or MCLG - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal or MRDLG: the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level or MRDL: the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Non-detects (ND) - lab analysis indicates that the contaminant is not present

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity, or cloudiness, of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is monitored because it is a good indicator of the effectiveness of our filtration system.

Level 1 assessment – a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 assessment – a very detailed study of the waterworks to identify potential problems and determine (if possible) why an *E. coli* PMCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Regulated Contaminants

Contaminant (units)	MCLG	MCL	Level Detected	Violation (Y/N)	Range	Date of Sample	Typical Source of Contamination
Turbidity	N/A	Lowest monthly percentage of samples meeting TT. Must be below 1.0NTU 100% of the time or below 0.30NTU 95% of the time	100% 0.05 NTU	N	0.02 – 0.05 NTU	2020	Soil Runoff
Fluoride	4.0 PPM	4.0 PPM	0.56 PPM	N	NA	8/11/2020	Erosion of natural deposits; water additive which promotes dental health
Nitrate/Nitrite	10 PPM	10 PPM	ND	N	N/A	2/10/2020	Runoff from fertilizer use; Leaching from septic tanks; Erosion of natural deposits; Sewage
Chlorine	MRDL= 4.0 PPM	MRDL= 4.0 PPM	1.00 PPM	N	0.60-2.00 PPM	2020	Water additive used to control microbes

*Total Trihalomethanes (TTHM)	N/A	80 PPB	57 PPB	N	16 – 89 PPB	2020	By product of water chlorination
*Haloacetic Acids (HAA)	N/A	60 PPB	48 PPB	N	19 – 71 PPB	2020	By product of water chlorination
Total Organic Carbon (TOC)	N/A	TT met when ≥ 1 or alternate criteria met	1.40	N	1.20-1.50	2020	Naturally present in the environment
Barium	2 PPM	2 PPM	0.013 PPM	N	N/A	8/11/2020	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

Contaminant (units)	MCLG	Action Level	90 th Percentile	Date of Sampling	# of Sampling Sites Exceeding Action Level	Typical Source of Contamination
Copper	1.3 PPM	1.3 PPM	0.114 PPM	06/2019-07/2019	0	Corrosion of household plumbing systems; erosion of natural deposits
Lead	15 PPB	15 PPB	5 PPB	06/2019-07/2019	0	Corrosion of household plumbing systems; erosion of natural deposits

Lead and Copper Contaminants

The water quality results in the above table are from testing done in 2019. However, the state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

Other Contaminants

Contaminants (Units)	Level Detected (Units)	Date of Sampling	Typical Source	Guidance
Sodium (Unregulated-No Limits Designated)	8.09 mg/L	8/11/2020	Naturally Occurring; Addition of treatment chemicals/processes	For individuals on a very low sodium diet (500 mg/day), EPA recommends that drinking-water sodium not exceed 20 mg/L. Should you have a health concern, contact your health care provider.

MCL's are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

ADDITIONAL HEALTH INFORMATION REGARDING LEAD IN DRINKING WATER: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Wise is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>

VIOLATIONS: None

CROSS CONNECTION SURVEY:

The Town of Wise is conducting a survey for residential and commercial customers and is asking that all residential and commercial customers participate. The survey pertains to the Town's Cross connection Program. The survey will help the Town further protect the water supply delivered to and consumed by all customers. To complete a survey contact: Caleb Ramsey @ 276.328.6353 or by Email: wisewtp@gmail.com

The Town of Wise is an Equal Opportunity Provider and Employer.

THIS REPORT WILL NO LONGER BE MAILED. IT WILL BE PUBLISHED IN THE COALFIELD PROGRESS ANNUALLY AND ONLINE AT <http://www.townofwise.net/documents-and-forms.html> .THE REPORT IS ALSO AVAILABLE UPON REQUEST BY CONTACTING CALEB RAMSEY AT 276-328-6353 OR BY EMAIL AT wisewtp@gmail.com